

# Metropolitan Water Treatment Plants - Treated Water Fluoride Concentration

For 1 August 2023 to 31 August 2023

	Ardmore WTP Treated A	Ardmore WTP Treated B1	Huia WTP Treated	Waikato WTP Treated	Waitakere WTP Treated*
	mg/L	mg/L	mg/L	mg/L	mg/L
2 August 2023			0.79	0.85	
7 August 2023	0.91	0.88	0.83		
9 August 2023				0.88	
10 August 2023					
14 August 2023			0.82		
15 August 2023	0.87	0.93			
16 August 2023				0.89	
21 August 2023	0.86	0.88			
22 August 2023			0.85		0.75
23 August 2023				0.8	
28 August 2023			0.87		0.84
29 August 2023	0.86	0.89		0.83	

## Metropolitan Water Treatment Plants - Treated Water Fluoride Concentration

### Note

Fluoride is added to Auckland's metropolitan water supply at the request of Auckland's legacy Councils. The Ministry of Health recommends that the fluoride content in New Zealand drinking water should be maintained in the range of 0.7 to 1.0mg/L for oral health reasons. Testing is carried out by an accredited laboratory using the Ion Selective Electrode method as per New Zealand's Drinking Water Standards.

(\*) Fluoride dosing at Waitakere WTP was stopped on the 16th July 2023 and remained out of service until the 21st August 2023, while maintenance work was conducted on the fluoride dosing system.