

Metropolitan Water Treatment Plants - Treated Water Fluoride Concentration

For 1 February 2023 to 28 February 2023

	Ardmore WTP Treated A	Ardmore WTP Treated B1	Huia WTP Treated	Waikato WTP Treated *	Waitakere WTP Treated
	mg/L	mg/L	mg/L	mg/L	mg/L
1 February 2023			0.75	0.64**	0.81
6 February 2023			0.82		0.89
7 February 2023	0.84	0.87			
8 February 2023				0.72	
13 February 2023			0.82		0.91
14 February 2023	0.88	0.88			
15 February 2023				0.68**	
20 February 2023			0.71		0.78
21 February 2023	0.89	0.9			
22 February 2023				0.53**	
27 February 2023			0.77		0.89
28 February 2023	0.83	0.81			

Metropolitan Water Treatment Plants - Treated Water Fluoride Concentration

Note

Fluoride is added to Auckland's metropolitan water supply at the request of Fluoride is added to Auckland's metropolitan water supply at the request of Auckland's legacy Councils. The Ministry of Health recommends that the fluoride content in New Zealand drinking water should be maintained in the range of 0.7 to 1.0mg/L for oral health reasons. Testing is carried out by an accredited laboratory using the Ion Selective Electrode method as per New Zealand's Drinking Water Standards.

(*) Represents the combined fluoride levels across both the Waikato and Waikato 50 sites (**) Fluoride dosing system maintenance occurring during the month of February resulted in lowered fluoride levels in the water