

Metropolitan Water Treatment Plants - Treated Water Fluoride Concentration

For 1 July 2023 to 31 July 2023

	Ardmore WTP Treated A	Ardmore WTP Treated B1	Huia WTP Treated	Waikato WTP Treated	Waitakere WTP Treated *
	mg/L	mg/L	mg/L	mg/L	mg/L
3 July 2023			0.74		0.83
4 July 2023	0.92	0.94			
6 July 2023				0.89	
10 July 2023	0.92	0.96	0.79		
11 July 2023					0.92
12 July 2023				0.8	
18 July 2023	0.88	0.88			
19 July 2023			0.74	0.8	
24 July 2023	0.9	0.88	0.79		
25 July 2023					
27 July 2023				0.87	
31 July 2023	0.89	0.95			

Metropolitan Water Treatment Plants - Treated Water Fluoride Concentration

Note

Fluoride is added to Auckland's metropolitan water supply at the request of Auckland's legacy Councils. The Ministry of Health recommends that the fluoride content in New Zealand drinking water should be maintained in the range of 0.7 to 1.0mg/L for oral health reasons. Testing is carried out by an accredited laboratory using the Ion Selective Electrode method as per New Zealand's Drinking Water Standards.

(*) Fluoride dosing at Waitakere WTP was stopped on the 16th July 2023 and remains out of service while maintenance work is conducted on the fluoride dosing system. It is currently projected that dosing will be restarted in mid to late August 2023