

For 1 June 2023 to 30 June 2023

| | Ardmore WTP Treated A | Ardmore WTP Treated B1 | Huia WTP Treated | Waikato WTP Treated ** | Waitakere WTP Treated |
|--------------|--------------------------|---------------------------|------------------|---------------------------|--------------------------|
| | mg/L | mg/L | mg/L | mg/L * | mg/L |
| 6 June 2023 | 0.89 | 0.85 | | | |
| 7 June 2023 | | | 0.63 | 0.92 | 0.9 |
| 12 June 2023 | | | 0.74 | | 0.84 |
| 13 June 2023 | 0.85 | 0.87 | | | |
| 14 June 2023 | | | | 0.86 | |
| 19 June 2023 | | | 0.86 | | 0.88 |
| 20 June 2023 | 0.88 | 0.89 | | | |
| 26 June 2023 | | | 0.8 | | 0.87 |
| 27 June 2023 | 0.81 | 0.81 | | | |
| 28 June 2023 | | | | 0.81 | |

Note

Fluoride is added to Auckland's metropolitan water supply at the request of Auckland's legacy Councils. The Ministry of Health recommends that the fluoride content in New Zealand drinking water should be maintained in the range of 0.7 to 1.0mg/L for oral health reasons. Testing is carried out by an accredited laboratory using the Ion Selective Electrode method as per New Zealand's Drinking Water Standards.

(*) Represents the combined fluoride levels across both the Waikato and Waikato 50 sites

(**) Waikato WTP was shut down for one week for routine annual maintenance and therefore has one fewer sample than normal.