

## Metropolitan Water Treatment Plants - Treated Water Fluoride Concentration

From: 01-Jul-2020 to 01-Aug-2020

	Ardmore WTP Treated A	Ardmore WTP Treated B1	Huia WTP Treated	Onehunga WTP Treated	Onehunga WTP Treated Water Hunua 3	Waikato WTP Treated	Waitakere WTP Treated
	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
6 July 2020	0.72	0.72	0.65	* 0.14	** 0.23		0.66
8 July 2020						0.67	
13 July 2020	0.76	0.75	0.65		0.79		0.7
14 July 2020						0.63	
20 July 2020	0.75	0.75	0.65		0.75		0.7
21 July 2020						0.64	
27 July 2020	0.74	0.75	0.66		0.78		0.7
28 July 2020						0.67	

### Note

Fluoride is added to Auckland's metropolitan water supply at the request of Auckland's legacy Councils. The Ministry of Health recommends that the fluoride content in New Zealand drinking water should be maintained in the range of 0.7 to 1.0mg/L for oral health reasons. Testing is carried out by an accredited laboratory using the Ion Selective Electrode method as per New Zealand's Drinking Water Standards.

(\*) Represents naturally occurring levels of Fluoride present in the water supplied to the Onehunga zone.

(\*\*) Represents naturally occurring levels of Fluoride in the water. Plant on local supply only so no fluoride dosing during this period.