

# Metropolitan Water Treatment Plants - Treated Water Fluoride Concentration

For 1 November 2023 to 30 November 2023

	Ardmore WTP Treated A	Ardmore WTP Treated B1	Huia WTP Treated	Papakura WTP Treated Water Tank	Waikato WTP Treated	Waitakere WTP Treated
	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
1 November 2023			N/A*		0.88	
6 November 2023	0.87					
7 November 2023						0.83
8 November 2023					0.78	
9 November 2023				0.79		
13 November 2023	0.87	0.88				
14 November 2023						0.9
15 November 2023					0.95	
16 November 2023				0.79		
20 November 2023	0.84	0.86				
21 November 2023						0.83
22 November 2023					0.94	
23 November 2023				0.78		
27 November 2023	0.92	0.88				
28 November 2023				0.79		0.85
29 November 2023					0.93	

## Metropolitan Water Treatment Plants - Treated Water Fluoride Concentration

### Note

Fluoride is added to Auckland's metropolitan water supply at the requirement of the Health (Fluoridation of Drinking Water) Act 2021.

The Ministry of Health recommends that the fluoride content in New Zealand drinking water should be maintained in the range of 0.7 to 1.0mg/L for oral health reasons. Testing is carried out by an accredited laboratory using the Ion Selective Electrode method as per New Zealand's Drinking Water Standards.

\*Fluoride dosing not available due to scheduled maintenance work. Ministry of Health has been notified as required under the Health (Fluoridation of Drinking Water) Amendment Act 2021